

Request For Information

Floyd Johnston Construction Co., Inc.
2301 Herndon Avenue
Clovis, CA 93611
Office: (559) 299-7373
Fax: (559) 298-3452
Contractor's License No. 280281

TO: GREG PIMENTAL
CITY OF LOS BANOS P.W. DEPT
411 MADISON AVE.
LOS BANOS CA 93635

DATE: 5-24-16

RFI# FJC #1

PROJECT: MERCY SPRINGS SEWER LINE REPLACEMENT

INFORMATION

REQUESTED: PLANS & SPECS STATE THAT CONTRACTOR
CAN CRUSH EXISTING PIPE IN PLACE. WILL
CITY ALLOW CONTRACTOR TO LAY NEW PIPE
ON GRADE WITH CRUSHED PIPE IN OR UNDER
IT?

FROM: STEVE LITTLE

REPLY

DATE: 5/26/16

AS NOTED IN MINUTES FROM THE PRE-BID MEETING, THE
EXISTING SEWER LINE WILL HAVE TO BE REMOVED IF
CONTRACTOR IS UNABLE TO MAKE SUBGRADE AND BACKFILL
MATERIAL STABLE WHEN SPOILS ARE MIXED OR CRUSHED IN
PLACE.

FROM: NZ

Request For Information

Floyd Johnston Construction Co., Inc.
2301 Herndon Avenue
Clovis, CA 93611
Office: (559) 299-7373
Fax: (559) 298-3452
Contractor's License No. 280281

TO: GREG PIMENTAL

DATE: 5-24-16

CITY OF LOS BANOS P.W. DEPT

411 MADISON AVE.

RFI# FR #2

LOS BANOS CA 93635

PROJECT: MERCEY SPRINGS SEWER LINE REPLACEMENT

INFORMATION

REQUESTED: WILL CITY ALLOW CONTRACTOR TO
GRIND EXISTING AC AND INCORPORATE INTO
BACKFILL MATERIAL?

FROM: STEVE LITTLE

REPLY

DATE: 5/26/16

YES, SEE CONSTRUCTION NOTE 5 ON SHEET 4 OF
THE PLANS.

FROM: N7

Request For Information

Floyd Johnston Construction Co., Inc.
2301 Herndon Avenue
Clovis, CA 93611
Office: (559) 299-7373
Fax: (559) 298-3452
Contractor's License No. 280281

TO: GREG PIMENTAL

DATE: 5-24-16

CITY OF LOS BANOS P.W. DEPT

411 MADISON AVE.

RFI# FJL #3

LOS BANOS CA 93635

PROJECT: MERCEY SPRINGS SEWER LINE REPLACEMENT

INFORMATION

REQUESTED: WHAT MAT'L IS EXISTING WATER
LINE "A.C. PIPE" ? WILL CONTRACTOR
BE RESPONSIBLE FOR DISPOSAL OF
A.C. PIPE (HAZARDOUS MAT'L) ?

FROM: STALE LITTLE

REPLY

DATE: 5/26/16

AS DISCUSSED AT PRE-BID MEETING AND AS NOTED IN PRE-BID
MEETING MINUTES, THE EXISTING WATERLINE THAT MAY REQUIRE ADJUSTMENTS
IS ACP. THE CONTRACTOR IS RESPONSIBLE FOR DISPOSING
ALL SPOILS AND ITEMS DEMOLISHED, INCLUDING A.C. PIPE.

FROM: N7

Request For Information

Floyd Johnston Construction Co., Inc.
2301 Herndon Avenue
Clovis, CA 93611
Office: (559) 299-7373
Fax: (559) 298-3452
Contractor's License No. 280281

TO: GREG PIMENTAL

DATE: 5-24-16

CITY OF LOS BANOS P.W. DEPT

411 MADISON AVE.

RFI# FJC #4

LOS BANOS CA 93635

PROJECT: MERCEY SPRINGS SEWER LINE REPLACEMENT

INFORMATION

REQUESTED: WHAT ARE FLOW RATES IN
EXISTING 10" BENTON PIPE? WHAT
TYPE OF PIPE IS EXISTING SEWER
PIPE?

FROM: _____

REPLY

DATE: 5/26/16

PER SECTION 6 OF THE TECHNICAL PROVISIONS, THE
CONTRACTOR SHALL ASSUME A FLOW RATE OF 150 GALLONS
PER MINUTE, AS NOTED IN THE PRE-BID MEETING MINUTES,
THE EXISTING SEWER LINE IS CLAY.

FROM: N7

Request For Information

Floyd Johnston Construction Co., Inc.

2301 Herndon Avenue
Clovis, CA 93611
Office: (559) 299-7373
Fax: (559) 298-3452
Contractor's License No. 280281

TO: GREG PIMENTAL
CITY OF LOS BANOS P.W. DEPT
411 MADISON AVE.
LOS BANOS CA 93635

DATE: 5.24-16

RFI # FJC #5

PROJECT: MERCY SPRINGS SEWER LINE REPLACEMENT

INFORMATION

REQUESTED: CONTRACTOR WILL REMOVE AND
REPLACE PIPE IN SAME TRENCH. WILL
CONTRACTOR BE REQUIRED TO PRESSURE TEST
AND T.V. NEW LINE. IF SO HOW WITH
LIVE CONNECTION?

FROM: STEVE LITTLE

REPLY

DATE: 5/26/16

PRESSURE TESTING REQUIREMENTS WILL BE WAIVED.
CITY INSPECTOR WILL DETERMINE ACCEPTANCE OF PIPELINE
INSTALLED.

FROM: N7

Request For Information

Floyd Johnston Construction Co., Inc.

2301 Herndon Avenue

Clovis, CA 93611

Office: (559) 299-7373

Fax: (559) 298-3452

Contractor's License No. 280281

TO: GREG PIMENTAL
CITY OF LOS BANOS P.W. DEPT
411 MADISON AVE.
LOS BANOS CA 93635

DATE: 5-24-16

RFI# FJC #6

PROJECT: MERCEY SPRINGS SEWER LINE REPLACEMENT

INFORMATION

REQUESTED: SPEC 6 STATES CONTRACTOR SHALL
FURNISH 2 SEWER VACUUM TRUCK TO BE
USED TO BYPASS FLOWS DURING WORKING HOURS.
WHERE WILL TRUCKS BE REQUIRED TO DUMP
INTO DURING WORKING HOURS?

FROM: _____

REPLY

DATE: 5/26/16

PER GENERAL NOTE 15 ON SHEET 2 OF THE PLANS, THE
SEWER VACUUM TRUCK WILL DUMP BACK INTO THE
SEWER SYSTEM AT A MANHOLE DESIGNATED BY THE
CITY.

FROM: N7

Request For Information

Floyd Johnston Construction Co., Inc.
2301 Herndon Avenue
Clovis, CA 93611
Office: (559) 299-7373
Fax: (559) 298-3452
Contractor's License No. 280281

TO: GREG PIMENTAL

DATE: 5-25-16

CITY OF LOS BANOS P.W. DEPT

411 MADISON AVE.

RFI # FJC # 7

LOS BANOS CA 93635

PROJECT: MERCEY SPRINGS SEWER LINE REPLACEMENT

INFORMATION

REQUESTED: NIGHT WORK HOURS ARE 10 PM TO 6 AM
OR 8 HOURS. WILL CONTRACTOR BE REQUIRED TO
REMOVE DETOUR (K-RAIL) COMPLETE BY 6⁰⁰ AM
SUN - THURSDAY ? THIS DOES NOT ALLOW
MUCH ACTUAL WORK TIME ?

FROM: STEVE LITTLE

REPLY

DATE: 5/26/16

PER TRAFFIC MANAGEMENT AND DETOUR NOTES NUMBER 9 ON
SHEET 2 OF THE PLANS, ROADWAYS SHALL BE RETURNED TO THEIR FULL
TRAFFIC USAGE BY REMOVAL OF ALL TRAFFIC CONTROL DEVICES USED
FOR TRAFFIC CONTROL OR DETOUR WHEN WORK IS NOT BEING PERFORMED,
THIS INCLUDE REMOVAL OF K-RAIL. WORKING HOURS ARE DESIGNATED BY Caltrans.

FROM: NT

Request For Information

Floyd Johnston Construction Co., Inc.
2301 Herndon Avenue
Clovis, CA 93611
Office: (559) 299-7373
Fax: (559) 298-3452
Contractor's License No. 280281

TO: GREG PIMENTAL

DATE: 5-25-16

CITY OF LOS BANOS P.W. DEPT

411 MADISON AVE.

RFI # FJC #8

LOS BANOS CA 93635

PROJECT: MERCEY SPRINGS SEWER LINE REPLACEMENT

INFORMATION

REQUESTED: NOTE 4 ON SHEET 2 OF THE PLANS STATES
THAT CONTRACTOR MUST HIRE A SERVICE TO
LOCATE ALL EXISTING CALTRANS UNDERGROUND FACILITIES.
IS THERE A LOCATE SERVICE LOCAL OR
ONE THAT CALTRANS CAN RECOMMEND?

FROM: STEVE LITV

REPLY

DATE: 5/26/16

CONTACT CALTRANS FOR THEIR PREFERRED LOCATE SERVICE.

FROM: WJ

Request For Information

Floyd Johnston Construction Co., Inc.

2301 Herndon Avenue

Clovis, CA 93611

Office: (559) 299-7373

Fax: (559) 298-3452

Contractor's License No. 280281

TO: GREG PIMENTAL

DATE: 5-25-16

CITY OF LOS BANOS P.W. DEPT

411 MADISON AVE.

RFI # FJC #9

LOS BANOS CA 93635

PROJECT: MERCEY SPRINGS SEWER LINE REPLACEMENT

INFORMATION

REQUESTED: SHEET 37 TRANCHING NOTE'S USE

AWWA C900 PIPE IN NOTE 6. WHAT

APPLIES TO SDR-35 PIPE? IS NOTE 2

TO BE USED FOR PIPE BACKFILL?

FROM: SP

REPLY

DATE: 5/26/16

~~THE~~ THE FLEXIBLE WALLED PIPE DETAIL APPLIES TO
SDR-35. NOTE 2 APPLIES TO SAND BACKFILL AROUND RIGID
WALLED PIPE. PER THE FLEXIBLE WALLED PIPE DETAIL, BACKFILL
MATERIAL AROUND PIPE IS CLASS 1 BACKFILL MATERIAL PER
ASTM D2321.

FROM: VF

Request For Information

Floyd Johnston Construction Co., Inc.
2301 Herndon Avenue
Clovis, CA 93611
Office: (559) 299-7373
Fax: (559) 298-3452
Contractor's License No. 280281

TO: GREG PIMENTAL
CITY OF LOS BANOS P.W. DEPT
411 MADISON AVE.
LOS BANOS CA 93635

DATE: 5-25-16

RFI# FJL #10

PROJECT: MERCY SPRINGS SEWER LINE REPLACEMENT

INFORMATION

REQUESTED: CITY STATES IN SPECS TO HAVE
2 VAC TRUCKS ON SITE AT ALL WORKING
HOURS. FLOW RATE OF 150 GPM MIN X 60 MIN
= 9000 GALLONS PER HOUR. WILL TWO VAC
TRUCK BE ABLE TO DO JOB?

FROM: [Signature]

REPLY

DATE: 5/26/16

CONTRACTOR NEEDS TO PROVIDE EQUIPMENT ABLE TO
PUMP SPECIFIED FLOWS.

FROM: N7

Request For Information

Floyd Johnston Construction Co., Inc.

2301 Herndon Avenue

Clovis, CA 93611

Office: (559) 299-7373

Fax: (559) 298-3452

Contractor's License No. 280281

TO: GREG PIMENTAL

DATE: 5-25-16

CITY OF LOS BANOS P.W. DEPT

411 MADISON AVE.

RFI # FJC # 11

LOS BANOS CA 93635

PROJECT: MERCEY SPRINGS SEWER LINE REPLACEMENT

INFORMATION

REQUESTED: SHEET 9 STATION 31+35.15

SHOWS A 6" SS LINE GOING INTO

A NEW SS MH. AND FLOWING DOWN

STREAM OF THAT. IS 6" LIVE? IS IT

ON A WYE? PLEASE CLARIFY

FROM: SP

REPLY

DATE: 5/26/16

THE EXISTING 6" SS LINE RUNS PARALLEL TO THE NEW 12"

SS LINE. THE PLANS DO NOT SHOW NOR DO THEY CALL OUT

FOR A 6" LINE TO BE TIED INTO MANHOLE ~~3072~~ 3072A.

(YOU MAY BE MISTAKING A CONTOUR LINE FOR A SS LINE).

FROM: _____

Request For Information

Floyd Johnston Construction Co., Inc.
2301 Herndon Avenue
Clovis, CA 93611
Office: (559) 299-7373
Fax: (559) 298-3452
Contractor's License No. 280281

TO: GREG PIMENTAL
CITY OF LOS BANOS P.W. DEPT
411 MADISON AVE.
LOS BANOS CA 93635

DATE: 5-25-16
RFI # FJL #12

PROJECT: MERCY SPRINGS SEWER LINE REPLACEMENT

INFORMATION

REQUESTED: CAN YOU POINT OUT THE
3 AREAS OF WATERMAIN ADJUSTMENTS
ALONG WITH SCOPE?

FROM: Steve Little

REPLY

DATE: 5/26/16

THE ITEM FOR WATERMAIN ADJUSTMENTS IS BASED ON THE
ASSUMPTION THAT EXISTING WATERMAIN CROSSINGS MAY BE REQUIRE
ADJUSTMENTS TO ACCOMMODATE THE NEW SS. LINE. LOCATIONS
FOR WATERMAIN ADJUSTMENTS WILL BE DETERMINED IN
THE FIELD.

FROM: _____

Request For Information

Floyd Johnston Construction Co., Inc.

2301 Herndon Avenue
Clovis, CA 93611
Office: (559) 299-7373
Fax: (559) 298-3452
Contractor's License No. 280281

TO: GREG PIMENTAL
CITY OF LOS BANOS P.W. DEPT
411 MADISON AVE.
LOS BANOS CA 93635

DATE: 5-25-16

RFI # FSL # 13

PROJECT: MERCEY SPRINGS SEWER LINE REPLACEMENT

INFORMATION

REQUESTED: THE PLANS SHOW THE NUMBER
OF TRAFFIC LOOPS TO BE REMOVED
AND REPAIRED. WHAT IF THIS NUMBER
OVER RUNS. WILL A CHANGE ORDER BE
CUT IF OVER RUN OCCURS

FROM: [Signature]

REPLY

DATE: 5/26/16

PLEASE REFER TO CONSTRUCTION NOTE 6 ON SHEET
10 AND 19 OF THE PLANS.

FROM: [Signature]

Request For Information

Floyd Johnston Construction Co., Inc.

2301 Herndon Avenue
Clovis, CA 93611
Office: (559) 299-7373
Fax: (559) 298-3452
Contractor's License No. 280281

TO: GREG PIMENTAL

DATE: 5-25-16

CITY OF LOS BANOS P.W. DEPT

411 MADISON AVE.

RFI # 52 14

LOS BANOS CA 93635

PROJECT: MERCEY SPRINGS SEWER LINE REPLACEMENT

INFORMATION

REQUESTED: CK COUNT ON MANHOLES

REMOVE

17 EACH

NEW MANHOLES

18 EACH

BID ITEM 7 SHOW REMOVE 9 REPLACE 16

FROM: [Signature]

REPLY

DATE: 5/26/16

MANHOLES REMOVED - 17

MANHOLES CONSTRUCTED - 16

ITEM 4 OF THE BID ITEMS DESCRIPTION STATES THAT THIS ITEM
WILL BE PAID PER MANHOLE CONSTRUCTED.

FROM: [Signature]