

ADDENDUM NO. 1

Date of Addendum: June 28, 2018

Project: G Street Waterline
Owner: City of Los Banos
Bid Date: July 10, 2018
To: Prospective Bidders
From: Gouveia Engineering
456 Sixth Street
Gustine, CA 95322

1. This Addendum forms a part of the Bidding Documents and will be incorporated into the Contract Documents, as applicable. All other conditions of the Contract Documents remain unchanged. The following changes, additions, or deletions as set forth herein shall apply to the Contract Documents and shall be made a part thereof and shall be subject to all the requirements thereof as though originally shown and/or specified.
2. The Plans are hereby modified to affect the following changes:
 - a. Drawing C-104
 - i. Revise construction note 4 to read: "VALVE TO REMAIN AND BE ABANDONED IN PLACE. THE PROCESS FOR ABANDONING THE VALVE IS:
 - 1) THE VALVE IS TO BE PLACED IN THE CLOSED POSITION.
 - 2) INSTALL A BLIND FLANGE AT THE EXISTING VALVE IF THE VALVE HAS A MECHANICAL CONNECTION, OR INSTALL A CAP AND CONCRETE KICKER IF THE EXISTING VALVE HAS A PUSH ON CONNECTION.
 - 3) THE BOX IS TO BE REMOVED.
 - 4) THE HOLE IS TO BE BACKFILLED AND THE PAVEMENT PATCHED."
 - b. Drawing C-111
 - ii. Revise construction note 5 to read: "VALVE TO REMAIN AND BE ABANDONED IN PLACE. THE PROCESS FOR ABANDONING THE VALVE IS:
 - 1) THE VALVE IS TO BE PLACED IN THE CLOSED POSITION.
 - 2) INSTALL A BLIND FLANGE AT THE EXISTING VALVE IF THE VALVE HAS A MECHANICAL CONNECTION, OR INSTALL A CAP AND CONCRETE KICKER IF THE EXISTING VALVE HAS A PUSH ON CONNECTION.
 - 3) THE BOX IS TO BE REMOVED.
 - 4) THE HOLE IS TO BE BACKFILLED AND THE PAVEMENT PATCHED."

3. Bids shall be submitted in accordance with this Addendum. All Bidders MUST acknowledge receipt of this Addendum by signing and returning this Addendum with your Bid.

Gouveia Engineering

Firm Name: _____


By: Mario B. Gouveia, PE

By: _____

Title: _____

Date: _____