

**ADDENDUM No. 2
(2 pages)**

LOS BANOS DOG PARK
CITY OF LOS BANOS

BID PACKAGE
PREPARED BY:



2816 Park Avenue
Merced, CA 95348
(209) 723-2066

DATE: MARCH 13, 2020

TO ALL HOLDERS OF PLANS, CONTRACT DOCUMENTS, AND SPECIFICATIONS:

This addendum forms a part of the Contract and modifies the original bidding documents as noted below:

Clarifications –

1. The successful bidder of this project shall have the following current and active California State Contractor's License at the time of the submission of the bid and throughout the duration of the contract: C27 – Landscape or Class A – General Contractor or Class B – General Building Contractor.

Questions from Bidders –

1. On the bid schedule, bid item # 17 calls for 5 ADA Ramps but the plans only show 4. Which is the correct quantity?


Response: There are 5 ramps. Two of the ramps share a landing with truncated domes.

2. The Irrigation Plan on Sheet L-1 indicates a 1-1/2" PVC line to potable water. Please provide the location and source of the potable water so we can determine the extent of the work.

Response: New 1-1/2" PVC water will connect underground to the hose bib piping at the existing structure, approximately 160' west of the proposed drinking fountains.

3. The Landscape Legend on Sheet L-1 calls out a symbol for the Dogi-Pot Pet Station #1003-L. However, due to scale of the plans, the symbol is very hard to locate. Please clarify the quantity of pet stations.

Response: There are two stations near the trash receptacles near the entrance.

Prepared by:  3-13-20
Spencer Supinger, P.E. Date

NOTE: Contractor must acknowledge receipt of this Addendum on their bid form.