



City of
Los Banos
At the Crossroads of California

ADDENDUM NO. 01

Date of Addendum: June 20, 2022

Project: Fairgrounds Area Waterline
Owner: City of Los Banos
Bid Date: August 16, 2022 at 2:00 p.m.
To: Prospective Bidders
From: City of Los Banos
Public Works Department
411 Madison Ave.
Los Banos, CA 93635

1. This Addendum forms a part of the Bidding Documents and will be incorporated into the Contract Documents, as applicable. All other conditions of the Contract Documents remain unchanged. The following changes, additions, or deletions as set forth herein shall apply to the Contract Documents and shall be made a part thereof and shall be subject to all the requirements thereof as though originally shown and/or specified.
2. The Contract Documents are hereby modified to affect the following changes:
 - a. The bid opening date has been changed to 2:00 p.m. on August 16, 2022. Replace the first paragraph of Advertisement for Bids sheet ½ with the following paragraph to extend the bid opening date: “Notice is hereby given that separate sealed bids for the award of contract for the **Construction of FAIRGROUNDS AREA WATERLINE** will be received by the City of Los Banos at the office of the City Clerk until 2:00 p.m. Pacific Daylight Time, August 16, 2022 and then at said office publicly opened and read aloud.”
 - b. Replace the first paragraph of Information to Bidders sheet 1/5 with the following paragraph to extend the bid opening date: “Sealed bids will be received by the City of Los Banos (herein called the “Owner”), at the office of the City Clerk until 2:00 p.m. Pacific Daylight Time (PDT), on August 16, 2022, then at said office, publicly opened and read aloud. Owner shall reject all bids received after the specified time and will return such bids to bidder, unopened. Bidders must submit bids in accordance with these instructions. No emailed or faxed bids will be accepted.”

PUBLIC WORKS DEPARTMENT
411 Madison Avenue
Los Banos, California 93635
209-827-7056

- c. Replace the fifth paragraph of the Pre-Bid Meeting section of Information for Bidders sheet 3/5 and the proposed timeline of events associated with the awarding of bid.

“Requests for clarification or questions shall be delivered to the Owner before 5:00 p.m. PDT on August 8, 2022. Any Owner response to a request for clarification, questions and answers and answers will be posted to the City’s website at www.losbanos.org no later than 5:00 p.m. PDT on August 11, 2022 and if necessary, shall become a part of the bid as an addendum.”

Proposed timeline of events associated with the awarding of bid:

Release of Advertisement for Bid		May 31, 2022
Pre-Bid Meeting – On Site – Mandatory	10:00 a.m.	June 9, 2022
Deadline to Submit Questions/Clarifications	5:00 p.m.	August 8, 2022
Addendum/Questions/Clarifications posted	5:00 p.m.	August 11, 2022
Bid Opening	2:00 p.m.	August 16, 2022
City Council Considers Bid		Sept. 21, 2022 (tentative)
Issuance of a Notice to Proceed	On or before:	Oct. 3, 2022 (tentative)
Construction to Begin	On or before:	Oct. 17, 2022 (tentative)

- d. Replace item 3 of the Sample Agreement sheet. A. 1/3 with the following paragraph to change liquidated damages to \$1,000.00 per calendar day:

“3. LIQUIDATED DAMAGES. Owner and Contractor recognize that time is of the essence of this Agreement and that the Owner will suffer financial loss if the work is not completed within the time specified in Paragraph 2 herein, plus any extensions thereof allowed in accordance with Paragraph 21, Time for Completion and Liquidated Damages, of the General Provisions. The parties also recognize the delays, expense and difficulties involved in proving in a legal proceeding the actual loss suffered by Owner if the work is not completed on time. Accordingly, instead of requiring any such proof, Owner and Contractor agree that as liquidated damages for delay (but not as a penalty) Contractor shall pay Owner One Thousand Dollars (\$1,000.00) for each day that passes after the time specified in Paragraph 2 herein.”

- e. Add the third paragraph of Section 6 Water Distribution Pipelines item 10, sheet Water Distribution Pipelines 3/4 with the following: “The chlorine solution shall then be introduced into the line at service connections or at such locations along the line that uniform distribution of chlorine throughout the line is insured, including services, fire hydrants and stubs. The line shall then be checked for contamination of a laboratory retained by the Owner and either accepted or rejected for use. In case of rejection, the chlorination process shall be repeated until the contamination test is satisfactory at no additional cost to the Owner. Initial testing will be paid by the City. Retesting of areas that failed the initial testing will be paid for by the Contractor.”

3. The Plans are hereby modified to effect the following changes:

- a. Drawing C-102
 i. Revise general note 24 to read:

PUBLIC WORKS DEPARTMENT
 411 Madison Avenue
 Los Banos, California 93635
 209-827-7056

“WHERE THE EDGE OF THE T-CUT ALONG TRENCH SECTION PARALLELS THE EXISTING CURB AND GUTTER OR EDGE OF PAVEMENT AND IS WITHIN 18” FROM THE EXISTING LIP OF GUTTER OR EDGE OF PAVEMENT, THE PAVEMENT SHALL BE REMOVED AND REPLACED TO THE LIP OF GUTTER OR EDGE OF PAVEMENT. REPLACE AB DISTURBED DURING CONSTRUCTION.”

b. Drawings C-104 to C-114

- i. Revise Surface Improvements Construction Note for removing and replacing AC to the following: “REMOVE AND REPLACE EXISTING AC 12 INCHES BEYOND ALL TRENCH WALLS. PLACE 4 INCHES OF AC WITHIN TRENCH SECTION. SAWCUT OR PROFILE EXISTING PAVEMENT IN NEAT, PARALLEL LINES FULL DEPTH OR 2 INCHES MINIMUM FOR T-CUT AND PLACE NEW AC.”

c. Drawing C-115, Detail 2, revise the trench repair section in paved areas as follows:

- i. Place 4 inches of AC above trench area.
- ii. Sawcut or profile existing pavement in neat, parallel lines full depth or 2 inches minimum for T-cut and place new AC.

4. Bids shall be submitted in accordance with this Addendum. All Bidders MUST acknowledge receipt of this Addendum by signing and returning this Addendum with your Bid.


City of Los Banos

Firm Name: _____

By: _____

Title: _____

Date: _____


6-20-22
By: Sokniorn Than, PE
Public Works Dir/City Engineer