



City of
Los Banos
At the Crossroads of California

ADDENDUM NO. 2

August 23, 2024

**Sunrise Ranch Park
Project No. 24-PK-0001**

The purpose of this addendum is to officially respond to questions as they relate to the Sunrise Ranch Park project.

1. **Question:** Sheet L 4.0 of the drawings call out for the concrete to be 2500 PSI 5 sack mix. On the Specs 2.8 Concrete Mixtures it calls out for the mix to be 3500 PSI. Can you please confirm which one is required?

Response: The Concrete PSI should be 2500.

This Addendum forms a part of the Proposal Documents and will be incorporated into the Contract Documents, as applicable. All other conditions of the Contract Documents remain unchanged. The following changes, additions, or deletions as set forth herein shall apply to the Contract Documents and shall be made a part thereof and shall be subject to all the requirements thereof as through originally shown and/or specified.

Proposals shall be submitted in accordance with this Addendum. All consultants **MUST** acknowledge receipt of this Addendum by signing and returning this Addendum with your Proposal.

City of Los Banos

By: Joe Heim
Parks and Recreation Director

Firm Name: _____

By: _____

Title: _____

Date: _____