

ADDENDUM NO. 1

TO CONTRACT DOCUMENTS

CITY OF LOS BANOS WELL 16 TEST WELL NO. 2

June 2, 2026

NOTICE TO BIDDERS

This Addendum is attached to and made a part of the above-entitled Contract Documents for the City of Los Banos with a bid opening at 2:00:00 P.M. on Wednesday, June 10, 2026, at the City of Los Banos Public Works Department located at 411 Madison Ave, Los Banos, CA 93635.

This **Addendum No.1** consists of five (5) pages and must be signed, dated, and submitted along with the Bid Documents.:

Response to Bidder's Questions

Item No. 1: Contractor Submitted General Questions

Question 1: Are there any access road limitations?

Answer: The access road consists of an approximately 20' wide dirt road that is typically utilized for farm equipment access. Access to this road is directly off of highway 152.

Question 2: Does the site have an unobstructed 20'x80' area with the proposed well being in the middle of the area?

Answer: The designated area for the well drilling process is measured as 125'x300' for drilling and disposal needs.

Question 3: Do you have photos of the site that can be provided prior to bidding?

Answer: No photos of the site are available at this time.

Question 4: Does the proposed site have any existing wells and, if so, can boring logs be provided to assist with the estimate?

Answer: The proposed site does not have any existing wells located on it, upon review of publicly available well records obtained from DWR's Well Completion Report Map Application, a couple of wells have been constructed nearby. Two driller's reports are included in Attachment 1 to this addendum.

Question 5: Please provide the expected construction start date.

Answer: Contractor is directed to refer to the project specifications "Information for Bidders" section, located on the City's website.

Question 6: Are all of the addenda that were provided during the previous bid process still valid for this bid process?

Answer: No, information provided from the previous bid process are not valid for this bid.

Question 7: Is a 20' conductor casing suitable to use?

Answer: Yes, a 20' conductor casing is suitable for use.

Question 8: Does the engineer have an approved contractor for E-log & Deviation?

Answer: No, the engineer does not have an approved contractor for E-log and Deviation.

Question 9: Are drilling fluids and cuttings to be disposed of on-site?

Answer: Yes, the drilling fluid and cuttings shall be disposed of on-site within the designated construction area and the site restored to the original grades per Specification 33 21 00.

Except as expressly amended hereby, all terms and conditions of the Contract Documents shall remain in full force and effect.

IN WITNESS WHEREOF, the parties hereto have executed this Addendum on _____, 2026.

CONTRACTOR

By: _____

ATTEST: _____

By:  _____

Stephen Spencer RCE 54634

PROVOST & PRITCHARD CONSULTING
GROUP

Attachment 1: Well Driller Logs

LSD Elev. 125

PEIS

10/10-17K1

L.F. No. 483

U. S. DEPARTMENT OF THE INTERIOR - BUREAU OF RECLAMATION - REGION II

WELL LOG

10/10-17K1

County Maricopa Owner _____ U.S.B.R. No. 10-10-17
 Dist. _____ Use Irrigation Local No. _____
 Quad. Valle Driller Joe Baker Date September 1949
 Location (.61 - .40)

Surf. Elev. 125 Groundwater Elev. _____ Date _____
 Depth 240 Groundwater Elev. _____ Date _____
 Yield _____ Aquifers _____
 Drawdown _____ Artesian head _____ Date _____
 Casing _____ % Sand-Gravel _____

Source of Data Driller Type Drill Rotary Diam. hole 30"

Depth	Elev.	Thick	Description
0	125	20	Top Soil 10 CF
20	105	17	Sand and gravel 17 G
37	88	7	Clay 7 C
44	81	9	Gravel 6/3 G
53	72	9	Clay 9 C
62	63	11	Sand and gravel 11 G
73	52	1	Clay 1 C
74	51	10	Sand 10 S
84	41	1	Clay 1 C
85	40	3	Sand (Some gravel) 5 G
90	35	10	Clay 10 C
100	25	3	Sand and gravel 3 G
103	22	5	Clay 5 C
108	17	2	Gravel 2 G
110	15	2	Clay 2 C
112	13	15	Gravel and clay streaks 15 F
127	-2	12	Clay 12 C
139	-14	18	Sand and Gravel 18 G
157	-22	10	Gravel 10 G
167	-42	12	Sand 12 S
179	-54	7	Clay 7 C
188	-61	14	Sand and gravel 14 G
200	-75	7	Gravel 7 G
207	-82	10	Clay 10 C
217	-92	13	Heavy gravel 13 G
230	-105	10	Clay 10 C
240	-115		Bottom

CONFIDENTIAL
 Water Cont. Sec. 13252

	50	100	200
G	23	19	47
S		10	12
F			15
Cu	10		
C	7	21	26
	40	50	100

WELL OWNER

ORIENTATION ()			XX VERTICAL _____ HORIZONTAL _____ ANGLE _____ (SPECIFY)		
DEPTH FROM SURFACE			DRILLING METHOD Reverse Rotary FLUID Water		
			DESCRIPTION		
Fl. to Fl.			Describe material, grain size, color, etc.		
0	3	Soil	Address 22011 W. Hwy 152 City Los Banos County Merced APN Book 33 Page 020 Parcel 032 Township _____ Range _____ Section _____ Latitude _____ NORTH _____ Longitude _____ WEST _____ DEG. MIN. SEC. DEG. MIN. SEC. LOCATION SKETCH NORTH WEST EAST SOUTH Illustrate or Describe Distance of Well from Roads, Buildings, Fences, Rivers, etc. and attach a map. Use additional paper if necessary. PLEASE BE ACCURATE & COMPLETE.		
3	23	Brown Clay			
23	25	Sand			
25	37	Gravel			
37	49	Gray Clay			
49	53	Sand			
53	100	Gray Clay			
100	135	Red Clay			
135	140	Sand			
140	153	Red Clay			
153	160	Sand			
160	165	Red Clay			
165	170	Sand			
170	180	Red Clay			
			ACTIVITY () X NEW WELL MODIFICATION/REPAIR _____ Deepen _____ Other (Specify) _____ DESTROY (Describe Procedures and Materials Under "GEOLOGIC LOG") PLANNED USES () WATER SUPPLY X Domestic _____ Public _____ Irrigation _____ Industrial MONITORING _____ TEST WELL _____ CATHODIC PROTECTION _____ HEAT EXCHANGE _____ DIRECT PUSH _____ INJECTION _____ VAPOR EXTRACTION _____ SPARGING _____ REMEDIATION _____ OTHER (SPECIFY) _____		
			WATER LEVEL & YIELD OF COMPLETED WELL DEPTH TO FIRST WATER _____ (Ft.) BELOW SURFACE DEPTH OF STATIC WATER LEVEL _____ (Ft.) & DATE MEASURED _____ ESTIMATED YIELD * _____ (GPM) & TEST TYPE _____ TEST LENGTH _____ (Hrs.) TOTAL DRAWDOWN _____ (Ft.) * May not be representative of a well's long-term yield.		
TOTAL DEPTH OF BORING 180 (Feet)					
TOTAL DEPTH OF COMPLETED WELL 170 (Feet)					

[illegible]

ATTACHMENTS (≤)

- ☐ Geologic Log
☐ Well Construction Diagram
☐ Geophysical Log(s)
☐ Soil/Water Chemical Analyses
☐ Other _____

ATTACH ADDITIONAL INFORMATION, IF IT EXISTS.

CERTIFICATION STATEMENT

I, the undersigned, certify that this report is complete and accurate to the best of my knowledge and belief.

QUALITY WELL DRILLERS

NAME (PERSON, FIRM, OR CORPORATION) TYPE OR PRINTED

Atwater, CA 95301

ADDRESS

CITY

STATE

71P

Signed

01/14/00
DATE SIGNED

468732
C-57 LICENSE NUMBER

WELL DRILLER/AUTHORIZED REPRESENTATIVE